

scheme	scheme type	indicator title	value	units	comments
Banana Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	0	Count	
Banana Water Supply	Potable water scheme	Length water mains	25.6	km	
Banana Water Supply	Potable water scheme	Capacity of water treatment plants	NR	ML/day	
Banana Water Supply	Potable water scheme	Total potable water storage volume	1.5	ML	
Banana Water Supply	Potable water scheme	Volume water lost: potable water	2.7	ML	
Banana Water Supply	Potable water scheme	Water main breaks per 100 km water main	7.8	per 100 km water main	
Banana Water Supply	Potable water scheme	Water service complaints per 1000 connections	69	per 1000 connections	
Banana Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	11.5	per 1000 connections	
Banana Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	80.5	per 1000 connections	
Banana Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	23	per 1000 connections	
Banana Water Supply	Potable water scheme	Connected residential properties: water	0.072	000s	
Banana Water Supply	Potable water scheme	Connected non-residential properties: water	0.015	000s	
Banana Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Banana Water Supply	Potable water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Banana Water Supply	Potable water scheme	Fixed charge: water value	786	\$/annum	
Banana Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Banana Water Supply	Potable water scheme	Volume water sourced: surface water	NR	ML	
Banana Water Supply	Potable water scheme	Volume water sourced: groundwater	NR	ML	
Banana Water Supply	Potable water scheme	Maximum daily demand	0.4	ML/day	
Banana Water Supply	Potable water scheme	Volume all water imported: internal and external	46.5	ML	Imported from Moura
Banana Water Supply	Potable water scheme	Volume all water exported: internal and external	0	ML	
Banana Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	NR	ML	
Banana Water Supply	Potable water scheme	Volume potable water supplied: residential	22.3	ML	
Banana Water Supply	Potable water scheme	Volume potable water supplied: non-residential	21.1	ML	
Banana Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Banana Water Supply	Potable water scheme	Volume water sourced: all	46.5	ML	
Banana Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Banana Water Supply	Potable water scheme	Water restriction duration: Level 1	365	days	This is correct
Banana Water Supply	Potable water scheme	Water restriction duration: Level 2	0	days	
Banana Water Supply	Potable water scheme	Water restriction duration: Level 3	0	days	
Banana Water Supply	Potable water scheme	Water restriction duration: Level 4	0	days	
Banana Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Banana Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Banana Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Banana Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Banana Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Banana Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Banana Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Banana Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Banana Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Banana Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Trucking water in is only option for contingency supply.
Baralaba Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	1	Count	
Baralaba Water Supply	Potable water scheme	Length water mains	14.1	km	
Baralaba Water Supply	Potable water scheme	Capacity of water treatment plants	1.1	ML/day	
Baralaba Water Supply	Potable water scheme	Total potable water storage volume	1.2	ML	
Baralaba Water Supply	Potable water scheme	Volume water lost: potable water	8.3	ML	

Baralaba Water Supply	Potable water scheme	Water main breaks per 100 km water main	14.2	per 100 km water main	
Baralaba Water Supply	Potable water scheme	Water service complaints per 1000 connections	44.1	per 1000 connections	
Baralaba Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	19.6	per 1000 connections	
Baralaba Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	63.7	per 1000 connections	
Baralaba Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	9.8	per 1000 connections	
Baralaba Water Supply	Potable water scheme	Connected residential properties: water	0.155	000s	
Baralaba Water Supply	Potable water scheme	Connected non-residential properties: water	0.049	000s	
Baralaba Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Baralaba Water Supply	Potable water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Baralaba Water Supply	Potable water scheme	Fixed charge: water value	819	\$/annum	
Baralaba Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Baralaba Water Supply	Potable water scheme	Volume water sourced: surface water	168.3	ML	
Baralaba Water Supply	Potable water scheme	Volume water sourced: groundwater	NR	ML	
Baralaba Water Supply	Potable water scheme	Maximum daily demand	0.6	ML/day	
Baralaba Water Supply	Potable water scheme	Volume all water imported: internal and external	0	ML	
Baralaba Water Supply	Potable water scheme	Volume all water exported: internal and external	0	ML	
Baralaba Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	115.9	ML	
Baralaba Water Supply	Potable water scheme	Volume potable water supplied: residential	42.6	ML	
Baralaba Water Supply	Potable water scheme	Volume potable water supplied: non-residential	65	ML	
Baralaba Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Baralaba Water Supply	Potable water scheme	Volume water sourced: all	168.3	ML	There was significant backwashing when addressing treatment performance until membranes changed. There was no recycling of supernatant back to head of plant. Also, investigating potential metering inaccuracies.
Baralaba Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Baralaba Water Supply	Potable water scheme	Water restriction duration: Level 1	365	days	This is correct
Baralaba Water Supply	Potable water scheme	Water restriction duration: Level 2	0	days	
Baralaba Water Supply	Potable water scheme	Water restriction duration: Level 3	0	days	
Baralaba Water Supply	Potable water scheme	Water restriction duration: Level 4	0	days	
Baralaba Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Baralaba Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Baralaba Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Baralaba Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Baralaba Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Baralaba Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Baralaba Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Baralaba Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Baralaba Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Baralaba Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Trucking water in is only option for contingency supply.
Biloela Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	1	Count	
Biloela Water Supply	Potable water scheme	Length water mains	92.4	km	
Biloela Water Supply	Potable water scheme	Capacity of water treatment plants	8.64	ML/day	
Biloela Water Supply	Potable water scheme	Total potable water storage volume	18	ML	
Biloela Water Supply	Potable water scheme	Volume water lost: potable water	400.5	ML	Under investigation, potential metering inaccuracies and undetected leaks.
Biloela Water Supply	Potable water scheme	Water main breaks per 100 km water main	24.9	per 100 km water main	

					Complaint total will be reviewed this year. Currently recording all calls/emails not necessarily complaints but notifications are being included. Next years will be reduced.
Biloela Water Supply	Potable water scheme	Water service complaints per 1000 connections	80	per 1000 connections	
Biloela Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	3.5	per 1000 connections	
Biloela Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	85.1	per 1000 connections	
Biloela Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	8.9	per 1000 connections	
Biloela Water Supply	Potable water scheme	Connected residential properties: water	2.2	000s	
Biloela Water Supply	Potable water scheme	Connected non-residential properties: water	0.374	000s	
Biloela Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Biloela Water Supply	Potable water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Biloela Water Supply	Potable water scheme	Fixed charge: water value	750	\$/annum	
			Fixed access charge with 2 tier usage charge	Text	
Biloela Water Supply	Potable water scheme	Fixed charge: water description			
Biloela Water Supply	Potable water scheme	Volume water sourced: surface water	951.8	ML	
Biloela Water Supply	Potable water scheme	Volume water sourced: groundwater	719.6	ML	
Biloela Water Supply	Potable water scheme	Maximum daily demand	8.2	ML/day	
Biloela Water Supply	Potable water scheme	Volume all water imported: internal and external	0	ML	
Biloela Water Supply	Potable water scheme	Volume all water exported: internal and external	65.3	ML	
Biloela Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	944.2	ML	
Biloela Water Supply	Potable water scheme	Volume potable water supplied: residential	667.6	ML	
Biloela Water Supply	Potable water scheme	Volume potable water supplied: non-residential	317.8	ML	
Biloela Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Biloela Water Supply	Potable water scheme	Volume water sourced: all	1671.4	ML	
Biloela Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Biloela Water Supply	Potable water scheme	Water restriction duration: Level 1	164	days	
Biloela Water Supply	Potable water scheme	Water restriction duration: Level 2	201	days	
Biloela Water Supply	Potable water scheme	Water restriction duration: Level 3	0	days	
Biloela Water Supply	Potable water scheme	Water restriction duration: Level 4	0	days	
Biloela Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Biloela Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Biloela Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Biloela Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Biloela Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Biloela Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Biloela Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Biloela Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Biloela Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	Ongoing drought conditions, declining levels in Callide Dam, Groundwater dependent on replenishment from Callide Dam.
Biloela Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Water potentially available from Awoonga Dam.. Council obtains water from both Callide Dam and Callide Aquifer. Potential also for additional bores.
Callide Dam Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	0	Count	
Callide Dam Water Supply	Potable water scheme	Length water mains	2.1	km	
Callide Dam Water Supply	Potable water scheme	Capacity of water treatment plants	NR	ML/day	
Callide Dam Water Supply	Potable water scheme	Total potable water storage volume	NR	ML	
Callide Dam Water Supply	Potable water scheme	Volume water lost: potable water	0.6	ML	
Callide Dam Water Supply	Potable water scheme	Water main breaks per 100 km water main	0	per 100 km water main	
Callide Dam Water Supply	Potable water scheme	Water service complaints per 1000 connections	120	per 1000 connections	
Callide Dam Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	40	per 1000 connections	
Callide Dam Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	160	per 1000 connections	

Callide Dam Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	0	per 1000 connections	
Callide Dam Water Supply	Potable water scheme	Connected residential properties: water	0.02	000s	
Callide Dam Water Supply	Potable water scheme	Connected non-residential properties: water	0.005	000s	
Callide Dam Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Callide Dam Water Supply	Potable water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Callide Dam Water Supply	Potable water scheme	Fixed charge: water value	750	\$/annum	
Callide Dam Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Callide Dam Water Supply	Potable water scheme	Volume water sourced: surface water	NR	ML	
Callide Dam Water Supply	Potable water scheme	Volume water sourced: groundwater	NR	ML	
Callide Dam Water Supply	Potable water scheme	Maximum daily demand	0.3	ML/day	
Callide Dam Water Supply	Potable water scheme	Volume all water imported: internal and external	19.6	ML	Imported from Biloela
Callide Dam Water Supply	Potable water scheme	Volume all water exported: internal and external	0	ML	
Callide Dam Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	NR	ML	
Callide Dam Water Supply	Potable water scheme	Volume potable water supplied: residential	10	ML	
Callide Dam Water Supply	Potable water scheme	Volume potable water supplied: non-residential	9.7	ML	
Callide Dam Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Callide Dam Water Supply	Potable water scheme	Volume water sourced: all	19.6	ML	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: Level 1	164	days	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: Level 2	201	days	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: Level 3	0	days	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: Level 4	0	days	
Callide Dam Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Callide Dam Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Callide Dam Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Callide Dam Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Callide Dam Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Callide Dam Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Callide Dam Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Callide Dam Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Callide Dam Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	Ongoing drought conditions, declining levels in Callide Dam, Groundwater dependent on replenishment from Callide Dam.
Callide Dam Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Water available from Awoonga Dam
Goovigen Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	0	Count	
Goovigen Water Supply	Potable water scheme	Length water mains	5.2	km	
Goovigen Water Supply	Potable water scheme	Capacity of water treatment plants	NR	ML/day	
Goovigen Water Supply	Potable water scheme	Total potable water storage volume	0.2	ML	
Goovigen Water Supply	Potable water scheme	Volume water lost: potable water	1.9	ML	
Goovigen Water Supply	Potable water scheme	Water main breaks per 100 km water main	38.8	per 100 km water main	
Goovigen Water Supply	Potable water scheme	Water service complaints per 1000 connections	53.6	per 1000 connections	
Goovigen Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Goovigen Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	53.6	per 1000 connections	
Goovigen Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	35.7	per 1000 connections	
Goovigen Water Supply	Potable water scheme	Connected residential properties: water	0.035	000s	
Goovigen Water Supply	Potable water scheme	Connected non-residential properties: water	0.021	000s	
Goovigen Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Goovigen Water Supply	Potable water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Goovigen Water Supply	Potable water scheme	Fixed charge: water value	692	\$/annum	

			Fixed access charge with 2 tier usage charge	Text	
Goovigen Water Supply	Potable water scheme	Fixed charge: water description			
Goovigen Water Supply	Potable water scheme	Volume water sourced: surface water	NR	ML	
Goovigen Water Supply	Potable water scheme	Volume water sourced: groundwater	16.3	ML	
Goovigen Water Supply	Potable water scheme	Maximum daily demand	0.2	ML/day	
Goovigen Water Supply	Potable water scheme	Volume all water imported: internal and external	0	ML	
Goovigen Water Supply	Potable water scheme	Volume all water exported: internal and external	0	ML	
Goovigen Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	NR	ML	
Goovigen Water Supply	Potable water scheme	Volume potable water supplied: residential	8.6	ML	
Goovigen Water Supply	Potable water scheme	Volume potable water supplied: non-residential	4.6	ML	
Goovigen Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Goovigen Water Supply	Potable water scheme	Volume water sourced: all	16.3	ML	
Goovigen Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Goovigen Water Supply	Potable water scheme	Water restriction duration: Level 1	0	days	
Goovigen Water Supply	Potable water scheme	Water restriction duration: Level 2	365	days	This is correct
Goovigen Water Supply	Potable water scheme	Water restriction duration: Level 3	0	days	
Goovigen Water Supply	Potable water scheme	Water restriction duration: Level 4	0	days	
Goovigen Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Goovigen Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Goovigen Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Goovigen Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Goovigen Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Goovigen Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Goovigen Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Goovigen Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Goovigen Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	
Goovigen Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Trucking water in is only option for contingency supply.
Moura Water Supply	Potable water scheme	Number water treatment plants: providing full treatment	1	Count	
Moura Water Supply	Potable water scheme	Length water mains	35.9	km	
Moura Water Supply	Potable water scheme	Capacity of water treatment plants	7.2	ML/day	
Moura Water Supply	Potable water scheme	Total potable water storage volume	5.5	ML	
Moura Water Supply	Potable water scheme	Volume water lost: potable water	103.6	ML	Under investigation, potential metering inaccuracies and undetected leaks.
Moura Water Supply	Potable water scheme	Water main breaks per 100 km water main	13.9	per 100 km water main	
Moura Water Supply	Potable water scheme	Water service complaints per 1000 connections	42.6	per 1000 connections	
Moura Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections	9.9	per 1000 connections	
Moura Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections	61.4	per 1000 connections	
Moura Water Supply	Potable water scheme	Average frequency unplanned interruptions: water	5	per 1000 connections	
Moura Water Supply	Potable water scheme	Connected residential properties: water	0.879	000s	
Moura Water Supply	Potable water scheme	Connected non-residential properties: water	0.13	000s	
Moura Water Supply	Potable water scheme	Percent CSS response target met: water incidents	100	%	
Moura Water Supply	Potable water scheme	Water quality complaints per 1000 connections	2	per 1000 connections	
Moura Water Supply	Potable water scheme	Fixed charge: water value	786	\$/annum	
			Fixed access charge with 2 tier usage charge	Text	
Moura Water Supply	Potable water scheme	Fixed charge: water description			
Moura Water Supply	Potable water scheme	Volume water sourced: surface water	599.2	ML	
Moura Water Supply	Potable water scheme	Volume water sourced: groundwater	NR	ML	
Moura Water Supply	Potable water scheme	Maximum daily demand	3.2	ML/day	
Moura Water Supply	Potable water scheme	Volume all water imported: internal and external	0	ML	

Moura Water Supply	Potable water scheme	Volume all water exported: internal and external		46.5	ML	
Moura Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant		516.5	ML	
Moura Water Supply	Potable water scheme	Volume potable water supplied: residential		267.7	ML	
Moura Water Supply	Potable water scheme	Volume potable water supplied: non-residential		97.1	ML	
Moura Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR		ML	
Moura Water Supply	Potable water scheme	Volume water sourced: all		599.2	ML	
Moura Water Supply	Potable water scheme	Water restriction duration: PWCM	NR		days	
Moura Water Supply	Potable water scheme	Water restriction duration: Level 1		365	days	This is correct
Moura Water Supply	Potable water scheme	Water restriction duration: Level 2		0	days	
Moura Water Supply	Potable water scheme	Water restriction duration: Level 3		0	days	
Moura Water Supply	Potable water scheme	Water restriction duration: Level 4		0	days	
Moura Water Supply	Potable water scheme	Water restriction duration: Level 5	NR		days	
Moura Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes		yes/no	
Moura Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes		yes/no	
Moura Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes		yes/no	
Moura Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes		yes/no	
Moura Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes		yes/no	
Moura Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		4	1,2,3,4,5,6	
Moura Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	unsure		high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Moura Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure		high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Moura Water Supply	Potable water scheme	Available contingency supplies	no		yes/no	
Taroom Water Supply	Potable water scheme	Number water treatment plants: providing full treatment		0	Count	
Taroom Water Supply	Potable water scheme	Length water mains		32.1	km	
Taroom Water Supply	Potable water scheme	Capacity of water treatment plants		0.9	ML/day	
Taroom Water Supply	Potable water scheme	Total potable water storage volume		1.55	ML	
Taroom Water Supply	Potable water scheme	Volume water lost: potable water		83.7	ML	Under investigation, potential metering inaccuracies and undetected leaks.
Taroom Water Supply	Potable water scheme	Water main breaks per 100 km water main		3.1	per 100 km water main	
Taroom Water Supply	Potable water scheme	Water service complaints per 1000 connections		20.6	per 1000 connections	
Taroom Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections		7.5	per 1000 connections	
Taroom Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections		30	per 1000 connections	
Taroom Water Supply	Potable water scheme	Average frequency unplanned interruptions: water		1.9	per 1000 connections	
Taroom Water Supply	Potable water scheme	Connected residential properties: water		0.414	000s	
Taroom Water Supply	Potable water scheme	Connected non-residential properties: water		0.119	000s	
Taroom Water Supply	Potable water scheme	Percent CSS response target met: water incidents		100	%	
Taroom Water Supply	Potable water scheme	Water quality complaints per 1000 connections		0	per 1000 connections	
Taroom Water Supply	Potable water scheme	Fixed charge: water value		574	\$/annum	
Taroom Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge		Text	
Taroom Water Supply	Potable water scheme	Volume water sourced: surface water		0	ML	
Taroom Water Supply	Potable water scheme	Volume water sourced: groundwater		257.6	ML	
Taroom Water Supply	Potable water scheme	Maximum daily demand		1.6	ML/day	
Taroom Water Supply	Potable water scheme	Volume all water imported: internal and external		0	ML	
Taroom Water Supply	Potable water scheme	Volume all water exported: internal and external		0	ML	
Taroom Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant		237.6	ML	
Taroom Water Supply	Potable water scheme	Volume potable water supplied: residential		105.1	ML	
Taroom Water Supply	Potable water scheme	Volume potable water supplied: non-residential		49.5	ML	
Taroom Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR		ML	
Taroom Water Supply	Potable water scheme	Volume water sourced: all		257.6	ML	

Taroom Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Taroom Water Supply	Potable water scheme	Water restriction duration: Level 1		365 days	This is correct
Taroom Water Supply	Potable water scheme	Water restriction duration: Level 2		0 days	
Taroom Water Supply	Potable water scheme	Water restriction duration: Level 3		0 days	
Taroom Water Supply	Potable water scheme	Water restriction duration: Level 4		0 days	
Taroom Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	
Taroom Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Taroom Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Taroom Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Taroom Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Taroom Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Taroom Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		5 1,2,3,4,5,6	
Taroom Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
Taroom Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
Taroom Water Supply	Potable water scheme	Available contingency supplies	no	yes/no	location too isolated from other schemes. Council is modifying treatment to allow use of 2nd bore from Great Artesian Basin (need to oxidise higher levels of iron)
Thangool Water Supply	Potable water scheme	Number water treatment plants: providing full treatment		0 Count	
Thangool Water Supply	Potable water scheme	Length water mains		16.7 km	
Thangool Water Supply	Potable water scheme	Capacity of water treatment plants	NR	ML/day	
Thangool Water Supply	Potable water scheme	Total potable water storage volume		0.3 ML	
Thangool Water Supply	Potable water scheme	Volume water lost: potable water		0.9 ML	
Thangool Water Supply	Potable water scheme	Water main breaks per 100 km water main		6 per 100 km water main	
Thangool Water Supply	Potable water scheme	Water service complaints per 1000 connections		72.4 per 1000 connections	
Thangool Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections		0 per 1000 connections	
Thangool Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections		85.5 per 1000 connections	
Thangool Water Supply	Potable water scheme	Average frequency unplanned interruptions: water		6.6 per 1000 connections	
Thangool Water Supply	Potable water scheme	Connected residential properties: water		0.132 000s	
Thangool Water Supply	Potable water scheme	Connected non-residential properties: water		0.02 000s	
Thangool Water Supply	Potable water scheme	Percent CSS response target met: water incidents		100 %	
Thangool Water Supply	Potable water scheme	Water quality complaints per 1000 connections		13.2 per 1000 connections	
Thangool Water Supply	Potable water scheme	Fixed charge: water value		750 \$/annum	
Thangool Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Thangool Water Supply	Potable water scheme	Volume water sourced: surface water	NR	ML	
Thangool Water Supply	Potable water scheme	Volume water sourced: groundwater	NR	ML	
Thangool Water Supply	Potable water scheme	Maximum daily demand		0.3 ML/day	
Thangool Water Supply	Potable water scheme	Volume all water imported: internal and external		45.8 ML	imported from Biloela
Thangool Water Supply	Potable water scheme	Volume all water exported: internal and external		0 ML	
Thangool Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant	NR	ML	
Thangool Water Supply	Potable water scheme	Volume potable water supplied: residential		39 ML	
Thangool Water Supply	Potable water scheme	Volume potable water supplied: non-residential		6.3 ML	
Thangool Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR	ML	
Thangool Water Supply	Potable water scheme	Volume water sourced: all		45.8 ML	
Thangool Water Supply	Potable water scheme	Water restriction duration: PWCM	NR	days	
Thangool Water Supply	Potable water scheme	Water restriction duration: Level 1		164 days	
Thangool Water Supply	Potable water scheme	Water restriction duration: Level 2		201 days	
Thangool Water Supply	Potable water scheme	Water restriction duration: Level 3		0 days	
Thangool Water Supply	Potable water scheme	Water restriction duration: Level 4		0 days	
Thangool Water Supply	Potable water scheme	Water restriction duration: Level 5	NR	days	

Thangool Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Thangool Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Thangool Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Thangool Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Thangool Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Thangool Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		4	1,2,3,4,5,6
Thangool Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	fair		high,fair,unsure,low,very low
Thangool Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure		high,fair,unsure,low,very low
Thangool Water Supply	Potable water scheme	Available contingency supplies	yes	yes/no	Ongoing drought conditions, declining levels in Callide Dam, Groundwater dependent on replenishment from Callide Dam.
Theodore Water Supply	Potable water scheme	Number water treatment plants: providing full treatment		1	Count
Theodore Water Supply	Potable water scheme	Length water mains		13.6	km
Theodore Water Supply	Potable water scheme	Capacity of water treatment plants		1.75	ML/day
Theodore Water Supply	Potable water scheme	Total potable water storage volume		1.2	ML
Theodore Water Supply	Potable water scheme	Volume water lost: potable water		54.9	ML
Theodore Water Supply	Potable water scheme	Water main breaks per 100 km water main		0	per 100 km water main
Theodore Water Supply	Potable water scheme	Water service complaints per 1000 connections		31.7	per 1000 connections
Theodore Water Supply	Potable water scheme	Water and sewerage billing and account complaints per 1000 connections		10.6	per 1000 connections
Theodore Water Supply	Potable water scheme	Water and sewerage complaints (all) per 1000 connections		45.8	per 1000 connections
Theodore Water Supply	Potable water scheme	Average frequency unplanned interruptions: water		0	per 1000 connections
Theodore Water Supply	Potable water scheme	Connected residential properties: water		0.21	000s
Theodore Water Supply	Potable water scheme	Connected non-residential properties: water		0.074	000s
Theodore Water Supply	Potable water scheme	Percent CSS response target met: water incidents		100	%
Theodore Water Supply	Potable water scheme	Water quality complaints per 1000 connections		0	per 1000 connections
Theodore Water Supply	Potable water scheme	Fixed charge: water value		786	\$/annum
Theodore Water Supply	Potable water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge		Text
Theodore Water Supply	Potable water scheme	Volume water sourced: surface water		164.8	ML
Theodore Water Supply	Potable water scheme	Volume water sourced: groundwater	NR		ML
Theodore Water Supply	Potable water scheme	Maximum daily demand		1	ML/day
Theodore Water Supply	Potable water scheme	Volume all water imported: internal and external		0	ML
Theodore Water Supply	Potable water scheme	Volume all water exported: internal and external		0	ML
Theodore Water Supply	Potable water scheme	Volume potable water produced at a water treatment plant		150.9	ML
Theodore Water Supply	Potable water scheme	Volume potable water supplied: residential		57.3	ML
Theodore Water Supply	Potable water scheme	Volume potable water supplied: non-residential		36.9	ML
Theodore Water Supply	Potable water scheme	Volume water sourced: desalination marine water	NR		ML
Theodore Water Supply	Potable water scheme	Volume water sourced: all		164.8	ML
Theodore Water Supply	Potable water scheme	Water restriction duration: PWCM	NR		days
Theodore Water Supply	Potable water scheme	Water restriction duration: Level 1		365	days
Theodore Water Supply	Potable water scheme	Water restriction duration: Level 2		0	days
Theodore Water Supply	Potable water scheme	Water restriction duration: Level 3		0	days
Theodore Water Supply	Potable water scheme	Water restriction duration: Level 4		0	days
Theodore Water Supply	Potable water scheme	Water restriction duration: Level 5	NR		days
Theodore Water Supply	Potable water scheme	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Theodore Water Supply	Potable water scheme	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Theodore Water Supply	Potable water scheme	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Theodore Water Supply	Potable water scheme	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	



Theodore Water Supply	Potable water scheme	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Theodore Water Supply	Potable water scheme	Months water supply remaining as at 30 June (KPI level)		4	1,2,3,4,5,6
Theodore Water Supply	Potable water scheme	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Theodore Water Supply	Potable water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Theodore Water Supply	Potable water scheme	Available contingency supplies	no	yes/no	Trucking water in is only option for contingency supply.
Cracow Water	Raw-Partially treated water	Length water mains		3.9	km
Cracow Water	Raw-Partially treated water	Water main breaks per 100 km water main		0	per 100 km water main
Cracow Water	Raw-Partially treated water	Water service complaints per 1000 connections		51.3	per 1000 connections
Cracow Water	Raw-Partially treated water	Water and sewerage billing and account complaints per 1000 connections		0	per 1000 connections
Cracow Water	Raw-Partially treated water	Water and sewerage complaints (all) per 1000 connections		51.3	per 1000 connections
Cracow Water	Raw-Partially treated water	Connected residential properties: water		0.036	000s
Cracow Water	Raw-Partially treated water	Connected non-residential properties: water		0.003	000s
Cracow Water	Raw-Partially treated water	Percent CSS response target met: water incidents		100	%
Cracow Water	Raw-Partially treated water	Water quality complaints per 1000 connections		0	per 1000 connections
Cracow Water	Raw-Partially treated water	Fixed charge: water value		818.64	\$/annum
Cracow Water	Raw-Partially treated water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge		Text
Cracow Water	Raw-Partially treated water	Volume water sourced: surface water	NR		ML
Cracow Water	Raw-Partially treated water	Volume water sourced: groundwater	NR		ML
Cracow Water	Raw-Partially treated water	Maximum daily demand		0	ML/day
Cracow Water	Raw-Partially treated water	Volume all water imported: internal and external		3.1	ML
Cracow Water	Raw-Partially treated water	Volume all water exported: internal and external		0	ML
Cracow Water	Raw-Partially treated water	Volume water sourced: desalination marine water	NR		ML
Cracow Water	Raw-Partially treated water	Volume water sourced: all		3.1	ML
Cracow Water	Raw-Partially treated water	Volume raw-PT water supplied: residential		1.8	ML
Cracow Water	Raw-Partially treated water	Volume raw-PT water supplied: non-residential		1.1	ML
Cracow Water	Raw-Partially treated water	Water restriction duration: PWCM	NR		days
Cracow Water	Raw-Partially treated water	Water restriction duration: Level 1		365	days
Cracow Water	Raw-Partially treated water	Water restriction duration: Level 2		0	days
Cracow Water	Raw-Partially treated water	Water restriction duration: Level 3		0	days
Cracow Water	Raw-Partially treated water	Water restriction duration: Level 4		0	days
Cracow Water	Raw-Partially treated water	Water restriction duration: Level 5	NR		days
Cracow Water	Raw-Partially treated water	Has asset management planning been undertaken in the last 10 yrs?	yes		yes/no
Cracow Water	Raw-Partially treated water	Has drought management planning been undertaken in the last 10 yrs?	yes		yes/no
Cracow Water	Raw-Partially treated water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes		yes/no
Cracow Water	Raw-Partially treated water	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes		yes/no
Cracow Water	Raw-Partially treated water	Has the timing for potential future supply augmentation been assessed in the last 10	yes		yes/no
Cracow Water	Raw-Partially treated water	Months water supply remaining as at 30 June (KPI level)		4	1,2,3,4,5,6
Cracow Water	Raw-Partially treated water scheme	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Cracow Water	Raw-Partially treated water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	This is a reflection on the nature of the Dawson River Schemes, on stream storage limitations, and dependence on regular rainfall.
Cracow Water	Raw-Partially treated water scheme	Available contingency supplies	yes		yes/no
Wowan Water	Raw-Partially treated water	Length water mains		5.6	km
Wowan Water	Raw-Partially treated water	Water main breaks per 100 km water main		0	per 100 km water main

Wowan Water	Raw-Partially treated water	Water service complaints per 1000 connections	78.4	per 1000 connections	
Wowan Water	Raw-Partially treated water	Water and sewerage billing and account complaints per 1000 connections	9.8	per 1000 connections	
Wowan Water	Raw-Partially treated water	Water and sewerage complaints (all) per 1000 connections	88.2	per 1000 connections	
Wowan Water	Raw-Partially treated water	Connected residential properties: water	0.078	000s	
Wowan Water	Raw-Partially treated water	Connected non-residential properties: water	0.024	000s	
Wowan Water	Raw-Partially treated water	Percent CSS response target met: water incidents	100	%	
Wowan Water	Raw-Partially treated water	Water quality complaints per 1000 connections	0	per 1000 connections	
Wowan Water	Raw-Partially treated water	Fixed charge: water value	534	\$/annum	
Wowan Water	Raw-Partially treated water scheme	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Wowan Water	Raw-Partially treated water	Volume water sourced: surface water	NR	ML	
Wowan Water	Raw-Partially treated water	Volume water sourced: groundwater	22	ML	
Wowan Water	Raw-Partially treated water	Maximum daily demand	0.3	ML/day	
Wowan Water	Raw-Partially treated water	Volume all water imported: internal and external	0	ML	
Wowan Water	Raw-Partially treated water	Volume all water exported: internal and external	0	ML	
Wowan Water	Raw-Partially treated water	Volume water sourced: desalination marine water	NR	ML	
Wowan Water	Raw-Partially treated water	Volume water sourced: all	22	ML	
Wowan Water	Raw-Partially treated water	Volume raw-PT water supplied: residential	7.2	ML	
Wowan Water	Raw-Partially treated water	Volume raw-PT water supplied: non-residential	4.4	ML	
Wowan Water	Raw-Partially treated water	Water restriction duration: PWCM	NR	days	
Wowan Water	Raw-Partially treated water	Water restriction duration: Level 1	365	days	This is correct
Wowan Water	Raw-Partially treated water	Water restriction duration: Level 2	0	days	
Wowan Water	Raw-Partially treated water	Water restriction duration: Level 3	0	days	
Wowan Water	Raw-Partially treated water	Water restriction duration: Level 4	0	days	
Wowan Water	Raw-Partially treated water	Water restriction duration: Level 5	NR	days	
Wowan Water	Raw-Partially treated water	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Wowan Water	Raw-Partially treated water	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Wowan Water	Raw-Partially treated water	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Wowan Water	Raw-Partially treated water	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Wowan Water	Raw-Partially treated water	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	
Wowan Water	Raw-Partially treated water	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Wowan Water	Raw-Partially treated water scheme	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	Limited data available to provide any real confidence given drought conditions experienced.
Wowan Water	Raw-Partially treated water scheme	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	Limited data available to provide any real confidence given drought conditions experienced.
Wowan Water	Raw-Partially treated water scheme	Available contingency supplies	yes	yes/no	Trucking water in is only option for contingency supply.
Biloela Recycled Water	Recycled water scheme	Length water mains	0.4	km	
Biloela Recycled Water	Recycled water scheme	Water main breaks per 100 km water main	0	per 100 km water main	
Biloela Recycled Water	Recycled water scheme	Water service complaints per 1000 connections	0	per 1000 connections	
Biloela Recycled Water	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Biloela Recycled Water	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Biloela Recycled Water	Recycled water scheme	Connected residential properties: water	0	000s	
Biloela Recycled Water	Recycled water scheme	Connected non-residential properties: water	0.002	000s	
Biloela Recycled Water	Recycled water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Biloela Recycled Water	Recycled water scheme	Fixed charge: water value	NR	\$/annum	
Biloela Recycled Water	Recycled water scheme	Fixed charge: water description	NR	Text	
Biloela Recycled Water	Recycled water scheme	Volume all water imported: internal and external	0	ML	
Biloela Recycled Water	Recycled water scheme	Volume all water exported: internal and external	0	ML	
Biloela Recycled Water	Recycled water scheme	Volume recycled sewage supplied: all	350.6	ML	
Biloela Recycled Water	Recycled water scheme	Volume water sourced: all	350.7	ML	
Moura Recycled Water	Recycled water scheme	Length water mains	0.3	km	
Moura Recycled Water	Recycled water scheme	Water main breaks per 100 km water main	0	per 100 km water main	

Moura Recycled Water	Recycled water scheme	Water service complaints per 1000 connections	0	per 1000 connections	
Moura Recycled Water	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Moura Recycled Water	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Moura Recycled Water	Recycled water scheme	Connected residential properties: water	0	000s	
Moura Recycled Water	Recycled water scheme	Connected non-residential properties: water	0.001	000s	
Moura Recycled Water	Recycled water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Moura Recycled Water	Recycled water scheme	Fixed charge: water value	NR	\$/annum	
Moura Recycled Water	Recycled water scheme	Fixed charge: water description	NR	Text	
Moura Recycled Water	Recycled water scheme	Volume all water imported: internal and external	0	ML	
Moura Recycled Water	Recycled water scheme	Volume all water exported: internal and external	0	ML	
Moura Recycled Water	Recycled water scheme	Volume recycled sewage supplied: all	185.8	ML	
Moura Recycled Water	Recycled water scheme	Volume water sourced: all	185.9	ML	
Taroom Recycled Water	Recycled water scheme	Length water mains	0	km	
Taroom Recycled Water	Recycled water scheme	Water main breaks per 100 km water main	0	per 100 km water main	
Taroom Recycled Water	Recycled water scheme	Water service complaints per 1000 connections	0	per 1000 connections	
Taroom Recycled Water	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Taroom Recycled Water	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Taroom Recycled Water	Recycled water scheme	Connected residential properties: water	0	000s	
Taroom Recycled Water	Recycled water scheme	Connected non-residential properties: water	0.002	000s	
Taroom Recycled Water	Recycled water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Taroom Recycled Water	Recycled water scheme	Fixed charge: water value	NR	\$/annum	
Taroom Recycled Water	Recycled water scheme	Fixed charge: water description	NR	Text	
Taroom Recycled Water	Recycled water scheme	Volume all water imported: internal and external	0	ML	
Taroom Recycled Water	Recycled water scheme	Volume all water exported: internal and external	0	ML	
Taroom Recycled Water	Recycled water scheme	Volume recycled sewage supplied: all	69.7	ML	
Taroom Recycled Water	Recycled water scheme	Volume water sourced: all	69.7	ML	
Theodore Recycled Water	Recycled water scheme	Length water mains	0.1	km	
Theodore Recycled Water	Recycled water scheme	Water main breaks per 100 km water main	0	per 100 km water main	
Theodore Recycled Water	Recycled water scheme	Water service complaints per 1000 connections	0	per 1000 connections	
Theodore Recycled Water	Recycled water scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Theodore Recycled Water	Recycled water scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Theodore Recycled Water	Recycled water scheme	Connected residential properties: water	0	000s	
Theodore Recycled Water	Recycled water scheme	Connected non-residential properties: water	0.001	000s	
Theodore Recycled Water	Recycled water scheme	Water quality complaints per 1000 connections	0	per 1000 connections	
Theodore Recycled Water	Recycled water scheme	Fixed charge: water value	NR	\$/annum	
Theodore Recycled Water	Recycled water scheme	Fixed charge: water description	NR	Text	
Theodore Recycled Water	Recycled water scheme	Volume all water imported: internal and external	0	ML	
Theodore Recycled Water	Recycled water scheme	Volume all water exported: internal and external	0	ML	
Theodore Recycled Water	Recycled water scheme	Volume recycled sewage supplied: all	49.6	ML	
Theodore Recycled Water	Recycled water scheme	Volume water sourced: all	49.6	ML	
Biloela Sewerage	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main	3	per 100 km sewer mains	
Biloela Sewerage	Sewerage scheme	Number sewage treatment plants	1	Count	
Biloela Sewerage	Sewerage scheme	Length sewerage mains and channels	66.9	km	
Biloela Sewerage	Sewerage scheme	Sewerage service complaints per 1000 connections	0	per 1000 connections	
Biloela Sewerage	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Biloela Sewerage	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Biloela Sewerage	Sewerage scheme	Connected residential properties: sewerage	2.129	000s	
Biloela Sewerage	Sewerage scheme	Percent CSS response target met: sewerage incidents	100	%	
Biloela Sewerage	Sewerage scheme	Connected non-residential properties: sewerage	0.218	000s	
Biloela Sewerage	Sewerage scheme	Fixed charge: sewerage value	647.26	\$/annum	
Biloela Sewerage	Sewerage scheme	Fixed charge: sewerage description	access charge	Text	
Moura Sewerage	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main	6.4	per 100 km sewer mains	
Moura Sewerage	Sewerage scheme	Number sewage treatment plants	1	Count	
Moura Sewerage	Sewerage scheme	Length sewerage mains and channels	31.2	km	

Moura Sewerage	Sewerage scheme	Sewerage service complaints per 1000 connections	0	per 1000 connections	
Moura Sewerage	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Moura Sewerage	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Moura Sewerage	Sewerage scheme	Connected residential properties: sewerage	0.864	000s	
Moura Sewerage	Sewerage scheme	Percent CSS response target met: sewerage incidents	100	%	
Moura Sewerage	Sewerage scheme	Connected non-residential properties: sewerage	0.081	000s	
Moura Sewerage	Sewerage scheme	Fixed charge: sewerage value	713.76	\$/annum	
Moura Sewerage	Sewerage scheme	Fixed charge: sewerage description	access charge	Text	
Taroom Sewerage	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main	5.4	per 100 km sewer mains	
Taroom Sewerage	Sewerage scheme	Number sewage treatment plants	1	Count	
Taroom Sewerage	Sewerage scheme	Length sewerage mains and channels	18.5	km	
Taroom Sewerage	Sewerage scheme	Sewerage service complaints per 1000 connections	0	per 1000 connections	
Taroom Sewerage	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Taroom Sewerage	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Taroom Sewerage	Sewerage scheme	Connected residential properties: sewerage	0.324	000s	
Taroom Sewerage	Sewerage scheme	Percent CSS response target met: sewerage incidents	100	%	
Taroom Sewerage	Sewerage scheme	Connected non-residential properties: sewerage	0.111	000s	
Taroom Sewerage	Sewerage scheme	Fixed charge: sewerage value	660.2	\$/annum	
Taroom Sewerage	Sewerage scheme	Fixed charge: sewerage description	access charge	Text	
Theodore Sewerage	Sewerage scheme	Sewerage mains breaks/chokes per 100 km sewer main	0	per 100 km sewer mains	
Theodore Sewerage	Sewerage scheme	Number sewage treatment plants	1	Count	
Theodore Sewerage	Sewerage scheme	Length sewerage mains and channels	7.2	km	
Theodore Sewerage	Sewerage scheme	Sewerage service complaints per 1000 connections	0	per 1000 connections	
Theodore Sewerage	Sewerage scheme	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Theodore Sewerage	Sewerage scheme	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Theodore Sewerage	Sewerage scheme	Connected residential properties: sewerage	0.189	000s	
Theodore Sewerage	Sewerage scheme	Percent CSS response target met: sewerage incidents	100	%	
Theodore Sewerage	Sewerage scheme	Connected non-residential properties: sewerage	0.053	000s	
Theodore Sewerage	Sewerage scheme	Fixed charge: sewerage value	791.6	\$/annum	
Theodore Sewerage	Sewerage scheme	Fixed charge: sewerage description	access charge	Text	
Banana Shire Council WSP-	WSP	Number water treatment plants: providing full treatment	4	Count	
Banana Shire Council WSP-	WSP	Length water mains	248	km	
Banana Shire Council WSP-	WSP	Sewerage mains breaks/chokes per 100 km sewer main	4	per 100 km sewer mains	
Banana Shire Council WSP-	WSP	Number sewage treatment plants	4	Count	
Banana Shire Council WSP-	WSP	Capacity of water treatment plants	19.59	ML/day	
Banana Shire Council WSP-	WSP	Total potable water storage volume	29.45	ML	
Banana Shire Council WSP-	WSP	Length sewerage mains and channels	123.8	km	
Banana Shire Council WSP-	WSP	Volume water lost: potable water	657.1	ML	
Banana Shire Council WSP-	WSP	Water main breaks per 100 km water main	14.5	per 100 km water main	
Banana Shire Council WSP-	WSP	Water service complaints per 1000 connections	61.4	per 1000 connections	
Banana Shire Council WSP-	WSP	Sewerage service complaints per 1000 connections	0	per 1000 connections	
Banana Shire Council WSP-	WSP	Water and sewerage billing and account complaints per 1000 connections	6.5	per 1000 connections	
Banana Shire Council WSP-	WSP	Water and sewerage complaints (all) per 1000 connections	71.3	per 1000 connections	
Banana Shire Council WSP-	WSP	Average frequency unplanned interruptions: water	7.3	per 1000 connections	
Banana Shire Council WSP-	WSP	Connected residential properties: water	4.231	000s	
Banana Shire Council WSP-	WSP	Connected non-residential properties: water	0.834	000s	
Banana Shire Council WSP-	WSP	Connected residential properties: sewerage	3.506	000s	
Banana Shire Council WSP-	WSP	Percent CSS response target met: sewerage incidents	100	%	
Banana Shire Council WSP-	WSP	Percent CSS response target met: water incidents	100	%	
Banana Shire Council WSP-	WSP	Connected non-residential properties: sewerage	0.463	000s	
Banana Shire Council WSP-	WSP	Water quality complaints per 1000 connections	0.8	per 1000 connections	
Banana Shire Council WSP-	WSP	Revenue: all (NPR) water	7981.49	\$/,000	
Banana Shire Council WSP-	WSP	Nominal written down replacement cost: fixed sewerage assets	42982	\$/,000	
Banana Shire Council WSP-	WSP	Costs: operating water per connection	1232.4	\$/connection	

Banana Shire Council WSP-	WSP	Costs: operating sewerage per connection	610.92	\$/connection	
Banana Shire Council WSP-	WSP	Capital expenditure: water supply	6691.97	\$/,000	
Banana Shire Council WSP-	WSP	Capital expenditure: sewerage	1316.04	\$/,000	
Banana Shire Council WSP-	WSP	Revenue: all (NPR) sewerage	3633.24	\$/,000	
Banana Shire Council WSP-	WSP	Capital works grants: water	278	\$/,000	
Banana Shire Council WSP-	WSP	Capital works grants: sewerage	225	\$/,000	
Banana Shire Council WSP-	WSP	Costs: operating water (NPR)	6242.09	\$/,000	
Banana Shire Council WSP-	WSP	Costs: operating sewerage	2424.76	\$/,000	
Banana Shire Council WSP-	WSP	Costs: any other water	0	\$/,000	
Banana Shire Council WSP-	WSP	Costs: any other sewerage	0	\$/,000	
Banana Shire Council WSP-	WSP	Current replacement costs: fixed water assets	146593.17	\$/,000	
Banana Shire Council WSP-	WSP	Current replacement costs: fixed sewerage assets	85619.66	\$/,000	
Banana Shire Council WSP-	WSP	Costs: maintenance water	1412.59	\$/,000	
Banana Shire Council WSP-	WSP	Costs: maintenance sewerage	204.12	\$/,000	
Banana Shire Council WSP-	WSP	Current cost depreciation: water	3201.34	\$/,000	
Banana Shire Council WSP-	WSP	Current cost depreciation: sewerage	1657.4	\$/,000	
Banana Shire Council WSP-	WSP	Previous 5 year average annual renewals expenditure: water	1315.1	\$/,000	
Banana Shire Council WSP-	WSP	Previous 5 year average annual renewals expenditure: sewerage	214.6	\$/,000	
Banana Shire Council WSP-	WSP	Forecast 5 year average annual renewals expenditure: water	2690.35	\$/,000	
Banana Shire Council WSP-	WSP	Forecast 5 year average annual renewals expenditure: sewerage	1707.8	\$/,000	
Banana Shire Council WSP-	WSP	Nominal written down replacement cost: fixed water assets	89479.17	\$/,000	
Banana Shire Council WSP-	WSP	Fixed charge: water value	750	\$/annum	
Banana Shire Council WSP-	WSP	Fixed charge: sewerage value	647.26	\$/annum	
Banana Shire Council WSP-	WSP	Fixed charge: sewerage description	access charge	Text	
Banana Shire Council WSP-	WSP	Annual bill based on 200kL/a: water+sewerage	1767.26	\$/	
Banana Shire Council WSP-	WSP	Typical residential bill: water+sewerage	1999.03	\$/	
Banana Shire Council WSP-wide	WSP	Fixed charge: water description	Fixed access charge with 2 tier usage charge	Text	
Banana Shire Council WSP-	WSP	Volume water sourced: surface water	1884.1	ML	
Banana Shire Council WSP-	WSP	Volume water sourced: groundwater	1015.5	ML	
Banana Shire Council WSP-	WSP	Maximum daily demand	16	ML/day	
Banana Shire Council WSP-	WSP	Volume all water imported: internal and external	115.1	ML	
Banana Shire Council WSP-	WSP	Volume all water exported: internal and external	111.8	ML	
Banana Shire Council WSP-	WSP	Volume potable water produced at a water treatment plant	1965.1	ML	
Banana Shire Council WSP-	WSP	Volume recycled sewage supplied: all	655.7	ML	
Banana Shire Council WSP-	WSP	Volume potable water supplied: residential	1220.2	ML	
Banana Shire Council WSP-	WSP	Volume potable water supplied: non-residential	607.9	ML	
Banana Shire Council WSP-	WSP	Volume water sourced: desalination marine water	0	ML	
Banana Shire Council WSP-	WSP	Volume water sourced: all	3670.7	ML	
Banana Shire Council WSP-	WSP	Volume raw-PT water supplied: residential	9	ML	
Banana Shire Council WSP-	WSP	Volume raw-PT water supplied: non-residential	5.6	ML	
Banana Shire Council WSP-	WSP	Total full-time equivalent water+sewerage employees	39	FTEs	
Banana Shire Council WSP-	WSP	Water restriction duration: PWCM	NR	days	
Banana Shire Council WSP-	WSP	Water restriction duration: Level 1	365	days	
Banana Shire Council WSP-	WSP	Water restriction duration: Level 2	365	days	
Banana Shire Council WSP-	WSP	Water restriction duration: Level 3	0	days	
Banana Shire Council WSP-	WSP	Water restriction duration: Level 4	0	days	
Banana Shire Council WSP-	WSP	Water restriction duration: Level 5	NR	days	
Banana Shire Council WSP-	WSP	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Banana Shire Council WSP-	WSP	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Banana Shire Council WSP-	WSP	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Banana Shire Council WSP-	WSP	Has assessment of key capacity constraints of water infrastructure been undertaken in	yes	yes/no	
Banana Shire Council WSP-	WSP	Has the timing for potential future supply augmentation been assessed in the last 10	yes	yes/no	

Banana Shire Council WSP-	WSP	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Banana Shire Council WSP-wide	WSP	Confidence water demand will be met: next 18 mths	unsure	high,fair,unsure,low,very low	
Banana Shire Council WSP-wide	WSP	Confidence water demand will be met: next 5 yrs	unsure	high,fair,unsure,low,very low	
Banana Shire Council WSP-	WSP	Available contingency supplies	no	yes/no	